

New Construction: P. O. Box 38, Oakdale NY 11769-0901
(631) 218-1148

October 12, 2022

Michael Scanlon, PE
PW Grosser Consulting Inc.
630 Johnson Ave, Suite 7
Bohemia NY 11716

Re: Water Availability – 94 Dune Rd, East Quogue
SCTM # 0900-385-1-37.3
BP# 2000396886 Notification# 300090441

Dear Mr. Scanlon,

We have received your request for information regarding availability of public water service to the above referenced property.

Per your request, we have determined that there is an existing water main adjacent to the above captioned property from Dune Road and based upon the water requirements provided in your application and supplemental email dated August 18, 2022, the Suffolk County Water Authority (SCWA) has sufficient capacity to this property.

Connection fees which may not be our standard costs based on method of installation which could be directional drill or open cut are required. There may also be additional fees for restoration. Your client is required to submit a backflow application and request inspections for both backflow device and service lines. Any existing services that are no longer needed will have to be retired at your expense.



SCWA recommends the use of smart irrigation control systems and drought tolerant plantings to promote conservation and minimize the impact of peak pump age so as to ensure compliance with the SCWA Water Conservation Plan. SCWA prohibits the use of open loop geothermal systems.

If you have any further questions or would like to proceed with application for service, please contact our New Construction Department at (631) 218-1148 or the undersigned at (631) 563-5610. Please be advised that should your requirements for service increase at any time following the issuance of this letter, you are urged to contact this office.

This letter is not to be considered an action by SCWA as defined by the New York State Quality Review Act regulations or a determination that the parcel is approved for building. You are responsible for obtaining any other permits or approvals that may be required for the proposed project.

This letter of availability expires 10/12/24

Sincerely


Stephen Huber
Assistant Manager 

SH:lap